

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO: 6911-0067:173

Page 1 of 1

CATEGORY: Voice Communication System Control Unit

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

DESIGN: Models VOICECOM emergency voice evacuation, relocation, and paging system. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

101-CE-X	Comment Equipment Board
101-SPK	Speaker Module
101-STRB	Strobe Module
101-CHS	Common Equipment Chassis
101-PS/PS-MAIN/PS-AUX	Power Supply
101-AMP	Amplifier Driver
MM-1	Pre-Recorded Message Module
CAB-F	Enclosure

RATING: Primary: 120 VAC, 2A per power supply assembly
Secondary: 24 VDC, 6.5 - 26 Ah capacity

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model designation, electrical rating and UL label.

APPROVAL: Listed as voice communication/evacuation/relocation/paging system for use as a stand alone audio unit or with separately listed and electrically compatible fire alarm control unit.

XLF: 6911-1393:104

*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **OCTOBER 26, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager